



11/10/06 RE-ISSUED September 10, 2009

SIM / TECH FILTER  
KOTESKEY BROTHERS EXCAVATING INC.  
GARY KOTESKEY  
06598 HORTON BAY N RD.  
BOYNE CITY MI 49712

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (see also SEWAGE TREATMENT TANKS) \***  
Manufacturer: SIM / TECH FILTER  
Product Name: SEPTIC TANK GRAVITY FILTER  
Model Number(s): STF-110  
**[MAX. DWF 1200 GPD; FILTRATION > 1/16 IN. DIA.; INSTALL SINGLY OR MULTIPLES]**  
Product File No: 20060438

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of NOVEMBER 2011.**

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 1200 gallons per day.
- MAINTENANCE: Clean filter at inspection/pumping interval.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060438/20010540. This approval supersedes the approval issued on 11/10/2006 under product file number 20060438.

**\* This product type category has been changed to better reflect its use; it was previously approved as STA-sewage treatment apparatus; it is now listed as STAF- sewage treatment apparatus, effluent filter only.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov